



ENVIRONMENTAL
Transactions, Inc.

PO Box 279
River Edge, NJ 07661

December 20, 2021

Peter Sztaba
Tolland Public Schools
51 Tolland Green
Tolland, CT 06084


Dear Peter:

I have enclosed results for radon testing for your Birch Grove Primary School. As you can see, the results are below the EPA action level of 4.0 pCi/L. Based on these results, no further action need be taken. Re-testing should take place again in 5 years.

All rooms tested were done under closed conditions, with all windows shut and the HVAC system running under normal school use conditions in accordance with EPA and CT State guidelines.

Please call if you have questions. Thank you for using Environmental Transactions, Inc.

Sincerely,



Louis G. Esposito



STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH
RADON PROGRAM

INITIAL SCHOOL RADON MEASUREMENT REPORT FORM

*Please use the *Re-Evaluation Report Form* when performing 5-year re-evaluations.

May 2017

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel. **Do not send test results or other documents.** Submit this signed form by **mail, fax OR email (preferred)** to the Radon Program at:

CT Department of Public Health Radon Program
410 Capitol Avenue, MS #12 RAD
Hartford, CT 06134-0308
Fax: 860-509-7295
Email: DPH.RadonReports@ct.gov

Name of School:

Birch Grove primary school

Address:

(Street, town, zip code)

247 Rhodys Rd.
Tolland, CT 06084

Testing Company:

Environmental Transactions, Inc

Measurement Professional:

NRPP/NRSB Certification #:

Louis Esposito
5550001

Please provide the following summary information:

Dates of Testing:

(deployment & retrieval dates. Include confirmatory testing dates if necessary)

12/7/21 - 12/9/21

Total # of Rooms Tested

85

Total # of Rooms Requiring Re-Testing:

0

Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:

0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

[Signature]
Signature of Measurement Professional

[Signature] Peter Sufahr 12/22/21
Signature of School Designee Date

Facilities Director

Phone: (860) 509-7299
Telephone Device for the Deaf (860) 509-7191
450 Capitol Avenue - MS # 12RAD
P.O. Box 340308 Hartford, CT 06134
An Equal Opportunity Employer



Environmental Transaction

35 Mill Rd
Woodcliff Lake, NJ 07677
201-505-1010


Elouis77@aol.com

BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD, TOLLAND, CT, 6084

Vial #	Location	Start Date	Start Time	End Date	End Time	Radon Concentration (pCi/L)
5154922	RM C07	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5133446	RM C08	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5154770	RM C09	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5154843	RM C09 DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5154925	RM C11	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154621	RM C10	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5154813	RM C12	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154612	RM B08 DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154748	RM B07	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154686	RM C13	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.7
5154786	RM B10	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5133585	RM B09	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154845	RM A13	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154691	RM B12	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133579	RM A15	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154923	RM B11	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5133546	RM A16	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154874	RM B14	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5133597	RM A18	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154772	RM B13	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154792	RM A20	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133461	RM B16	12/07/2021	12:00 AM	12/09/2021	12:00 AM	1.6
5154837	RM A17	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4

5154768	CAFETERIA FRONT	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133475	RM A17 DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5154808	CAFETERIA REAR	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133434	RM A09	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154781	RM A22	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154802	RM A09 DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5150872	RM A22 BLANK	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5133590	RM A08A	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154809	RM A24	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133492	RM A19	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133499	RM A08B	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154619	KILN RM	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154849	RM A06C	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154603	RM C03	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5154635	RM E01	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154757	RM C04	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5150905	RM C04 BLANK	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5133563	RM E02	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133547	RM C05	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154928	RM E09	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133459	RM C06	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133596	RM E11	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154806	RM E04	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133409	MAIN OFFICE	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.7
5133548	RM E04 DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154605	RM B01B	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133593	RM E06	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5154830	RM E13	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5154825	RM B01C	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.9
5154742	RM E15	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5154888	RM E08	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154613	RM B01A	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133469	RM E09	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154660	RM B01D	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6

5154644	RM B01F	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154722	RM E09	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133529	RM A01A	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.8
5154893	RM D09	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5133594	RM A01C	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.8
5154887	RM D07	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.7
5154871	RM D08	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154880	RM A01C DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.9
5154763	RM D08 DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154702	GYM FRONT	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154805	GYM CENTER	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5133308	RM D01	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133567	GYM REAR	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5133389	RM D03	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154782	RM A02C	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5154910	RM D06	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5154894	RM A03A	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5070624	RM D06 BLANK	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5150879	RM A03A BLANK	12/07/2021	12:00 AM	12/09/2021	12:00 AM	<0.3
5154824	RM A05C	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5133317	RM D04	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154738	RM D04 DUP	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5133571	MEDIA CENTER RIGHT	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5154677	MEDIA CENTER LEFT	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.3
5133305	RM D03	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5
5154701	RM B05	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.4
5133424	RM B05C	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.6
5154856	RM B08	12/07/2021	12:00 AM	12/09/2021	12:00 AM	0.5



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400854
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133409	1ST FLOOR MAIN OFFICE	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 6:57 AM	0.7 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400857
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154605	1ST FLOOR RM B01B	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 7:27 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400862
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154825	1ST FLOOR RM B01C	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 7:17 AM	0.9 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400867
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154613	1ST FLOOR RM B01A	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 6:27 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400870
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154660	1ST FLOOR RM B01D	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 6:17 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400873
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154644	1ST FLOOR RM B01F	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 6:47 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400875
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133529	1ST FLOOR RM A01A	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 6:37 AM	0.8 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO-CURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400879
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133594	1ST FLOOR RM A01C	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 9:44 AM	0.8 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400883
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154880	1ST FLOOR RM A01C DUP	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 10:14 AM	0.9 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400886
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154702	1ST FLOOR GYM FRONT	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 10:04 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO-CURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400889
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154805	1ST FLOOR GYM CENTER	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 9:14 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400892
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133567	1ST FLOOR GYM REAR	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 9:04 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400895
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154782	1ST FLOOR RM A02C	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 7:57 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO-CURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400898
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154894	1ST FLOOR RM A03A	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 7:07 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400901
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5150879	1ST FLOOR RM A03A BLANK	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 1:03 PM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400902
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154824	1ST FLOOR RM A05C	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 8:24 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400908
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133571	1ST FLOOR MEDIA CENTER RIGHT	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 8:54 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400910
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154677	1ST FLOOR MEDIA CENTER LEFT	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 6:29 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400914
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154701	1ST FLOOR RM B05	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 7:19 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400917
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133424	1ST FLOOR RM B05C	Dec 07, 2021 2:30 PM	Dec 09, 2021 2:30 PM	Dec 11, 2021 7:49 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400920
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154856	1ST FLOOR RM B08	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 10:05 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400789
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154612	1ST FLOOR RM B08 DUP	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 9:54 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400792
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154748	1ST FLOOR RM B07	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 9:44 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400796
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154786	1ST FLOOR RM B10	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 10:14 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO-CURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400798
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133585	1ST FLOOR RM B09	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 10:04 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCIL) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400801
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154691	1ST FLOOR RM B12	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 9:14 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCIL) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400804
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154923	1ST FLOOR RM B11	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 9:04 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400807
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154874	1ST FLOOR RM B14	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 9:34 AM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400810
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154772	1ST FLOOR RMB13	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 9:24 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO-CURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400813
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133461	1ST FLOOR RM B16	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 8:34 AM	1.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400815
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154768	1ST FLOOR CAFETERIA FRONT	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 8:24 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO-CURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400817
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154808	1ST FLOOR CAFETERIA REAR	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 8:54 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400819
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133434	1ST FLOOR RM A09	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 8:44 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400821
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154802	1ST FLOOR RM A09 DUP	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 7:47 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400824
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133590	1ST FLOOR RM A08A	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 7:37 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400829
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133499	1ST FLOOR RM A08B	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 8:07 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO-CURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400831
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154849	1ST FLOOR RM A06C	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 7:07 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400833
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154603	1ST FLOOR RM C03	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 7:57 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400839
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154757	1ST FLOOR RM C04	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 6:57 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400841
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5150905	1ST FLOOR RM C04 BLANK	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 6:39 AM	< 0.3 pCi/L. **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400845
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133547	1ST FLOOR RM C05	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 3:50 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

RADON ANALYSIS REPORT

PRO-LAB™

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400848
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133459	1ST FLOOR RM C06	Dec 07, 2021 2:45 PM	Dec 09, 2021 2:40 PM	Dec 11, 2021 3:40 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER


Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007



James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400771
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154922	1ST FLOOR RM C07	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 3:31 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400774
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133446	1ST FLOOR RM C08	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 3:21 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L, you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400776
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154770	1ST FLOOR RM C09	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 2:31 AM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400778
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154843	1ST FLOOR RM C09 DUP	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 2:21 AM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400781
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154925	1ST FLOOR RM C11	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 6:19 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400783
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154621	1ST FLOOR RM C10	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 4:08 AM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400785
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154813	1ST FLOOR RM C12	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 4:18 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400794
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154686	1ST FLOOR RM C13	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 6:37 AM	0.7 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400799
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154845	1ST FLOOR RM A13	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 6:47 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400802
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133579	1ST FLOOR RM A15	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 6:17 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400805
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133546	1ST FLOOR RM A16	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 6:27 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO CURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400809
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133597	1ST FLOOR RM A18	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 5:47 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400811
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154792	1ST FLOOR RM A20	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 5:57 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400814
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154837	1ST FLOOR RM A17	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 5:27 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400816
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133475	1ST FLOOR RM A17 DUP	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 5:37 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400820
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154781	1ST FLOOR RM A22	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 5:17 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400822
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5150872	1ST FLOOR RM A22 BLANK	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 6:49 AM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400826
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154809	1ST FLOOR RM A24	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 4:47 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCIL) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400828
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133492	1ST FLOOR RM A19	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 4:57 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400830
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154619	1ST FLOOR KILN RM	Dec 07, 2021 3:10 PM	Dec 09, 2021 3:00 PM	Dec 11, 2021 7:17 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400834
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154635	1ST FLOOR RM E01	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 7:27 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400844
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133563	1ST FLOOR RM E02	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 4:27 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICO CURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400847
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154928	BASEMENT FLOOR <i>Rm E09</i>	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 3:30 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400849
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133596	1ST FLOOR RM E11	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 2:40 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400852
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154806	1ST FLOOR RM E04	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 2:50 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400855
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133548	1ST FLOOR RM E04 DUP	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 3:28 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400859
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133593	1ST FLOOR RM E06	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 3:18 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400861
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154830	1ST FLOOR RM E13	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 3:48 AM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400865
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154742	1ST FLOOR RM E15	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 3:38 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400866
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154888	1ST FLOOR RM E08	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 2:48 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400869
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133469	1ST FLOOR RM E09	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 2:38 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400874
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154722	1ST FLOOR RM 209 <i>NO</i>	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 3:08 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400877
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154893	1ST FLOOR RM D09	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 2:58 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCl/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400880
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154887	1ST FLOOR RM D07	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 2:08 AM	0.7 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400882
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154871	1ST FLOOR RM D08	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 1:58 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400885
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154763	1ST FLOOR RM D08 DUP	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 2:28 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400890
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133308	1ST FLOOR RM D01	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 5:35 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400893
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133389	1ST FLOOR RM D03	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 5:25 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400897
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154910	1ST FLOOR RM D06	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 5:55 AM	0.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400899
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5070624	1ST FLOOR RM D06 BLANK	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 8:56 AM	< 0.3 pCi/L **

** One or more analysis results fall under the Lower Limit of Detection of 0.3 pCi/L.

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV

RADON ANALYSIS REPORT



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400904
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133317	1ST FLOOR RM D04	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 9:34 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400906
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5154738	1ST FLOOR RM D04 DUP	Dec 07, 2021 3:20 PM	Dec 09, 2021 3:20 PM	Dec 11, 2021 7:29 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV



RADON ANALYSIS REPORT

1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

TEST ID NUMBER: 1400911
DATE RECEIVED: 12/10/2021
REPORT DATE: 12/21/2021

ENVIRONMENTAL TRANSACTION
35 Mill Rd
WOODCLIFF LAKE, NJ 07677

TEST LOCATION
BIRCH GROVE PRIMARY SCHOOL
247 RHODES RD
TOLLAND, CT 06084

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
5133305	1ST FLOOR RM D03	Dec 07, 2021 3:40 PM	Dec 09, 2021 3:35 PM	Dec 11, 2021 8:09 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.

Jose Figueroa, RMS
NRPP CERT # 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV